

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 150/2025-26

Dated: 7.5.2025

It is certified that an inspection team headed by Mr. Gopal Chandra Sharma, Senior Chemist

(Name of Officers with designation) from SIKAR PHED

inspected the Prince Academy of Higher Education, Sikar (Raj.)

(Name & Address of the school) on 3.5.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2025-2026/145 dated 5.05.2025

of (PHED Lab) certified that the

Prince Academy of Higher Education (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6.5.2026

Signature with Seal:

Name

Designation

Name & Address of the

  
Jitendra Lal Sharma  
वरिष्ठ रसायनज्ञ  
ऑफिस (प्रयोगशाला) विभाग

प्रयोगशाला, सीकर

To Prince Academy of Higher Education  
P.S. Was Road, Sikar (Raj.)  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 150/2025-26

Dated: 7.5.2025

It is certified that an inspection team headed by Mr. Lal. D. Patel, C.A., Sherpur, Senior Chemist

(Name of Officers with designation) from SIKAR PHED

inspected the Prince Academy of Higher Education, SIKAR (Raj.)

(Name & Address of the school) on 3.5.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2025-2026/145 dated 5.05.2025

of (PHED Lab) certified that the

Prince Academy of Higher Education (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6.5.2026

Signature with Seal:

Name

Designation

Name & Address of the Officer/ Department

To

Prince Academy of Higher Education

Palwas Road, SIKAR (Raj.)

(Name & Address of the Institution)

प्रयोगशाला, सीकर

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**OFFICE OF THE SENIOR CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY SIKAR  
REPORT OF THE CHEMICAL EXAMINATION OF WATER**

Not valid for legal case

Date - 05/05/2025

No. Lab/Tech(Private Chem.Rep)/2025-2026/145

To,

Principal  
Prince Academy Of Higher Education  
Palwas Road, Sikar (Raj.)

District: Sikar

Block : Dhod

Reference :Your Letter No-9714/2025/10732 Date-02.05.2025

Sample Collected By :- Mukesh

Date of Receipt : 02.05.2025

Source	Permissible value as per B.I.S. 10500/2012	RO	TW	
Source Location			Prince Academy Of Higher Education, Palwas Road	Prince Academy Of Higher Education, Palwas Road
Gram Panchayat		Nani	Nani	
Village/Town/ City		Nani	Nani	
Habitation	Desirable limit	Permissible limit in absence of alternate Source	Nani	Nani
Date of Collection			02.05.2025	02.05.2025
Date of Examination			05.05.2025	05.05.2025
Lab. Sample No.			82	83

Note :- All results Except pH are in mg/L

	6.5 to 8.5	No Relaxation	7.29	7.23
pH	1	5	Clear	Clear
Turbidity (NTU)	200	600	110	263
Total Alkalinity (as CaCO <sub>3</sub> )	200	600	55	333
Total Hardness (as CaCO <sub>3</sub> )	250	1000	64	530
Chloride (as Cl <sup>-</sup> )	45	45	23	38
Nitrates (as NO <sub>3</sub> <sup>-</sup> )	200	400	7	280
Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	1.0	1.5	0.18	0.09
Fluoride (as F <sup>-</sup> )	500	2000	238	725

Remarks:- Sample not collected by Lab

*Mukesh*

Senior Chemist  
PHED Lab, Sikar

जन स्वास्थ्य अभियंत्रण की  
Date

प्रयोगशाला, सीकर

No. Lab/Tech(Private Chem.Rep)/2025-2026

Copy to:

1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

Senior Chemist  
PHED Lab Sikar

**OFFICE OF THE SENIOR CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY SIKAR  
REPORT OF THE CHEMICAL EXAMINATION OF WATER**

Not valid for legal case

No. Lab/Tech(Private Chem.Rep)/2025-2026/145

Date - 05/05/2025

To,

Principal  
Prince Academy Of Higher Education  
Palwas Road, Sikar (Raj.)

District: Sikar  
Block : Dhod

Reference :Your Letter No-9714/2025/10732 Date-02.05.2025

Sample Collected By :- Mukesh

Date of Receipt : 02.05.2025

Source	Permissible value as per B.I.S. 10500/2012		RO	TW
Source Location			Prince Academy Of Higher Education, Palwas Road	Prince Academy Of Higher Education, Palwas Road
Gram Panchayat			Nani	Nani
Village/Town/ City			Nani	Nani
Habitation	Desirable limit	Permissible limit in absence of alternate Source	Nani	Nani
Date of Collection			02.05.2025	02.05.2025
Date of Examination			05.05.2025	05.05.2025
Lab. Sample No.			82	83

Note :- All results Except pH are in mg/L


	6.5 to 8.5	No Relaxation	7.29	7.23
pH	1	5	Clear	Clear
Turbidity (NTU)	200	600	110	263
Total Alkalinity (as CaCO <sub>3</sub> )	200	600	55	333
Total Hardness (as CaCO <sub>3</sub> )	250	1000	64	530
Chloride (as Cl <sup>-</sup> )	45	45	23	38
Nitrates (as NO <sub>3</sub> <sup>-</sup> )	200	400	7	280
Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	1.0	1.5	0.18	0.09
Fluoride (as F <sup>-</sup> )	500	2000	238	725
Total Dissolved Solids				

**Remarks:- Sample not collected by Lab**

No. Lab/Tech(Private Chem.Rep)/2025-2026

Copy to:

1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

  
 Senior Chemist  
 PHED Lab Sikar  
 जन स्वास्थ्य अभियांत्रिकी प्रयोगशाला, सीकर

Senior Chemist  
PHED Lab Sikar